



Saving Lives, Protecting Property.

RECOMMENDED PRACTICE ON UPGRADING RESTAURANT COOKING AREA FIRE PROTECTION SYSTEMS WITH NEW SYSTEMS MEETING THE UL 300 STANDARD

UL 300 is a standard developed by Underwriters Laboratories Inc. (UL) entitled "Fire Extinguishing Systems for Protection of Restaurant Cooking Areas". UL 300's effective date was November 21, 1994.

All new restaurant cooking area fire protection systems manufactured after the effective date must comply with UL 300 to qualify for a UL Listing.

UL 300 introduced several new major fire test protocol changes:

- The test appliance was changed from a fabricated pan (to simulate a fryer) to a commercial gas fryer with specified heating and cooling rates.
- The one-minute preburn after autoignition was changed to a two-minute preburn.
- The appliance "fuel-off" condition during preburn was changed to an appliance "fuel-on" condition.
- A minimum grease autoignition temperature of 685°F (363°C) was added.

This new test protocol more closely replicates the actual conditions expected to be found in commercial cooking operations.

RECOMMENDED PRACTICE

Manufacturers of restaurant cooking area fire protection systems have achieved more effective means of suppressing cooking area fires by developing equipment that meets the UL 300 requirements, keeping pace with changes made to cooking equipment, cooking media, and methodology. In the interest of promoting the use of the most current fire protection technology -- to protect lives, property, and the environment from harm by fire -- FEMA strongly recommends that pre-UL 300 restaurant cooking area fire protection systems be upgraded to a system that meets the UL 300 standard when:

- Any changes are made to the original installation of cooking appliances and the hoods/ducts within the protected area, or the addition of cooking appliances requiring protection, or a change to vegetable-based cooking oils; or

- The manufacturer of the restaurant cooking area fire protection system or another fire protection expert recommends upgrading the system; or
- The local enforcement authorities, insurance company, or other authority requires or recommends upgrading the system.

Always consult and follow the recommendations of your restaurant cooking area fire protection system manufacturer.

Prepared by the members of FEMA's Systems Division

Visit FEMA's website at www.femalifesafety.org for a list of members